

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES

Section: 06 50 00—Structural Plastics

REPORT HOLDER:

CERTAINTED CORPORATION

EVALUATION SUBJECT:

RESTORATION MILLWORK® EXTERIOR TRIM: TRIMBOARDS, SHEETS, BEADBOARD AND ONE-PIECE CORNERS

ADDITIONAL LISTEE:

CERTATRIM® by CERTAINTED CORPORATION

1.0 EVALUATION SCOPE

1.1 Compliance with the following codes:

- 2018, 2015 and 2012 *International Building Code*® (IBC)
- 2018, 2015 and 2012 *International Residential Code*® (IRC)
- 2013 *Abu Dhabi International Building Code* (ADIBC)†

†The ADIBC is based on the 2009 IBC. 2009 IBC code sections referenced in this report are the same sections in the ADIBC.

Properties evaluated:

- Weather resistance
- Termite resistance
- Surface-burning characteristics
- Structural—negative transverse wind loads

1.2 Evaluation to the following green code(s) and/or standards:

- 2019 California Green Building Standards Code (CALGreen), Title 24, Part 11
- 2015, 2012 and 2008 ICC 700 *National Green Building Standard*™ (ICC 700-2015, ICC 700-2012 and ICC 700-2008).

Attributes verified:

See Section 3.0

2.0 USES

Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim Trimboards, Sheets, Beadboard and One-Piece Corners are used as nonload-bearing exterior trim for construction types in accordance with Section 5.2.

3.0 DESCRIPTION

Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim Trimboards, Sheets, Beadboard and One-Piece Corners are rigid cellular PVC solid cross sections installed as corner boards, soffits, fascias, column wraps, door pilasters, frieze boards, nonload-bearing rake boards, architectural millwork, door trim and window trim.

The material is expanded rigid polyvinyl chloride with a small-cell micro-structure. Restoration Millwork® and CertaTrim® Trimboards, Sheets and One-Piece Corners are supplied in woodgrain and smooth surface textures. Restoration Millwork® and CertaTrim® Beadboard is supplied with a smooth surface. Restoration Millwork® and CertaTrim® Trimboards are available in nominal widths of 4 inches (102 mm) to 16 inches (406 mm) and nominal thicknesses of 5/8 inch (16 mm), 1 inch (25 mm) and 5/4 inches (32 mm). Restoration Millwork® and CertaTrim® Sheets are available in 4-foot (1.2 m) widths and in lengths of 8, 10, 12, 18 and 20 feet (2.4, 3.0, 3.7, 5.5 and 6.1 m), with actual thicknesses of 3/8, 1/2, 5/8, 3/4 and 1 inch (9.5, 12.7, 15.9, 19.1 and 25.4 mm). Restoration Millwork® and CertaTrim® Beadboard is available in 1/2-inch-thick-by-5 1/8-inch-wide-by-18-foot-long (12.7 mm by 130.1 mm by 5.4 m) segments, and 4-foot-by-8-foot wide (1.2 m by 2.4 m) sheets with a thickness of 1/2 inch (12.7 mm). Restoration Millwork® and CertaTrim® One-Piece Corners are available in a nominal thickness of 5/4 inches (31.8 mm) and nominal 4 inch (102 mm) and 6 inch (152 mm) outside corner sizes.

Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim, at a maximum nominal thickness of 1 inch (25.4 mm), has a flame-spread index of not more than 200 when tested in accordance with ASTM E84.

Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim has demonstrated equivalent termite resistance to that of an approved preservative-treated wood or naturally durable wood in accordance with the code.

The attributes of the Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim have been verified as conforming to the provisions of (i) CALGreen Section A4.405.1.1 for prefinished building materials and Section A5.406.1.2 for reduced maintenance; (ii) ICC 700-2015 and ICC 700-2012 Sections 602.1.6 and 11.602.1.6 for termite-resistant materials and Sections 601.7, 11.601.7, and 12.1(A).601.7 for site-applied finishing materials; and (iii) ICC 700-2008 Section 602.8 for termite-resistant materials and Section 601.7 for site-applied finishing materials. Note that decisions on compliance for those areas rest with the user of this report. The user is advised of the project-specific provisions that may be contingent upon meeting specific conditions, and the verification of those conditions is outside

ICC-ES Evaluation Reports are not to be construed as representing aesthetics or any other attributes not specifically addressed, nor are they to be construed as an endorsement of the subject of the report or a recommendation for its use. There is no warranty by ICC Evaluation Service, LLC, express or implied, as to any finding or other matter in this report, or as to any product covered by the report.

the scope of this report. These codes or standards often provide supplemental information as guidance.

4.0 INSTALLATION

4.1 General:

Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim Trimboards, Sheets, Beadboard and One-Piece Corners must be installed in accordance with the manufacturer's published installation instructions and this report. A copy of the instructions must be available at all times on the jobsite during installation. The instructions within this report must govern if there are any conflicts between the manufacturer's published installation instructions and this report.

4.2 Fasteners:

Nails must be stainless steel or hot-dipped galvanized. Fasteners must be approved 8d by 2½-inch (63.5 mm) box nails or finish nails, and must be designed for wood trim and wood siding. Nails must have blunt points and full round heads. The nails must be long enough to penetrate the solid wood substrate a minimum 1½ inches (38.1 mm). The nails located at board ends must be placed ¾ inch (19.1 mm) from the end of the board.

4.3 Wind Load Assemblies Using Restoration Millwork® and CertaTrim® Trimboards or Sheets:

4.3.1 Assembly No. 1—Soffit: Restoration Millwork® and CertaTrim® Trimboards or Sheets, with a minimum thickness of ¾ inch (19.1 mm), must be installed on minimum 2-by-4 wood framing, SPF stud grade (G = 0.42), spaced a maximum of 24 inches (609 mm) on center. The Restoration Millwork® and CertaTrim® Trimboards or Sheets are placed with the long direction perpendicular to the wood framing and are fastened to the wood framing with 8d by 2½-inch-long (63.5 mm) finish nails located 4 inches (101 mm) on center into each supporting framing member starting ¾ inch from the edge of the trim board. Trimboards or Sheets with a minimum thickness of ¾ inch (19.1 mm) have a maximum allowable design load of 21 psf (1.0 kN/m²) suction or negative pressure.

4.3.2 Assembly No. 2—Sheet: Restoration Millwork® and CertaTrim® Sheets, with a minimum thickness of ⅜-inch (9.5 mm), must be installed on minimum 2-by-4 wood framing, SPF stud grade (G = 0.42), spaced 16 inches (406 mm) on center. The Restoration Millwork® and CertaTrim® Sheets are fastened to the wood framing with 8d by 2½-inch-long (63.5 mm) finish nails located 4 inches (101 mm) on center around the perimeter and at each supporting framing member. Perimeter nailing must be located ¾ inch (19.1 mm) from the edge of the sheet. Sheets with a minimum thickness of ⅜ inch (9.5 mm) have a maximum allowable design load of 55 psf (2.6 kN/m²) suction or negative pressure.

4.3.3 Assembly No. 3—Trim: Restoration Millwork® and CertaTrim® Trimboards, with a minimum thickness of ⅝ inch (15.9 mm) and a maximum width of 12 inches (305 mm), must be installed on minimum 7/16-inch-thick (11.1 mm) OSB sheathing over 2-by-4 wood framing, SPF stud grade (G = 0.42), spaced 16 inches (406 mm) on center. The Restoration Millwork® and CertaTrim® Trimboards are fastened through the OSB sheathing to the stud framing with 8d by 2½-inch-long (63.5 mm) finish nails

located 16 inches (406 mm) on center lengthwise. Three nails must be placed at each supporting stud member. Trimboards with a minimum thickness of ⅝ inch (15.9 mm) have a maximum allowable design load of 26 psf (1.2 kN/m²) suction or negative pressure.

5.0 CONDITIONS OF USE

The Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim Trimboards, Sheets, Beadboard, and One-Piece Corners described in this report comply with, or are suitable alternatives to what is specified in, those codes listed in Section 1.0 of this report, subject to the following conditions:

- 5.1 This evaluation report and the manufacturer's published installation instructions must be submitted at the time of permit application.
- 5.2 The product is limited to the following construction types:
 - a. Nonload-bearing exterior trim on buildings of combustible nonfire-resistance-rated construction (Type VB) under the IBC.
 - b. All buildings permitted under the IRC.
- 5.3 The product must be installed over solid backing material, such as approved exterior sheathing, which is covered with an approved water-resistive barrier or approved exterior wall covering, or as otherwise noted in Section 4.0 of this report.

6.0 EVIDENCE SUBMITTED

Data in accordance with the ICC-ES Acceptance Criteria for Rigid Cellular PVC Nonload-bearing Exterior Trim (AC227), dated December 2004 (Editorially revised November 2017).

7.0 IDENTIFICATION

7.1 Each package of Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim Trimboards, Sheets, Beadboard, and One-Piece Corners described in this report must be labeled with the brand name (Restoration Millwork® or CertaTrim®), the CertainTeed Corporation name, and the evaluation report number (ESR-2922).

7.2 The report holder's contact information is the following:

CERTAINTEED CORPORATION
803 BELDEN ROAD
JACKSON, MICHIGAN 49203
(800) 233-8990
www.certainteed.com

7.3 The Additional Listee's contact information is the following:

CERTATRIM® by CERTAINTEED CORPORATION
20 MOORES ROAD
MALVERN, PA 19355
(800) 233-8990
www.certainteed.com

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 50 00—Structural Plastics

REPORT HOLDER:**CERTAINTED CORPORATION****EVALUATION SUBJECT:****RESTORATION MILLWORK® EXTERIOR TRIM: AND CERTATRIM® EXTERIOR TRIM: TRIMBOARDS, SHEETS, BEADBOARD AND ONE-PIECE CORNERS****1.0 REPORT PURPOSE AND SCOPE****Purpose:**

The purpose of this evaluation report supplement is to indicate that Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim: Trimboards, Sheets, Beadboard and One-piece Corners, recognized in ICC-ES master evaluation report ESR-2922, have also been evaluated for compliance with the code(s) noted below.

Applicable code editions:

- 2016 California Building Code (CBC)
- 2016 California Residential Code (CRC)

2.0 CONCLUSIONS**2.1 CBC:**

The Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim: Trimboards, Sheets, Beadboard and One-piece Corners, described in Sections 2.0 through 7.0 of the master evaluation report ESR-2922, comply with the CBC provided the design and installation are in accordance with the 2015 *International Building Code*® (IBC) provisions noted in the master report.

The products have not been evaluated under CBC Chapter 7A for use in the exterior design and construction of new buildings located in any Fire Hazard Severity Zone with State Responsibility Areas or any Wildland–Urban Interface Area.

2.2 CRC:

The Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim: Trimboards, Sheets, Beadboard and One-piece Corners, described in Sections 2.0 through 7.0 of the master evaluation report ESR-2922, comply with the CRC provided the design and installation are in accordance with the 2015 *International Residential Code*® (IRC) provisions noted in the master report.

The products have not been evaluated under CRC Section R337 for use in the exterior design and construction of new buildings located in any Fire Hazard Severity Zone with State Responsibility Areas or any Wildland–Urban Interface Area.

The products recognized in this supplement have not been evaluated for compliance with the 2015 *International Wildland–Urban Interface Code*®.

This supplement expires concurrently with the evaluation report, reissued February 2020.

DIVISION: 06 00 00—WOOD, PLASTICS AND COMPOSITES
Section: 06 50 00—Structural Plastics

REPORT HOLDER:

CERTAINTEED CORPORATION

EVALUATION SUBJECT:

RESTORATION MILLWORK® EXTERIOR TRIM AND CERTATRIM® EXTERIOR TRIM: TRIMBOARDS, SHEETS,
BEADBOARD AND ONE-PIECE CORNERS

1.0 REPORT PURPOSE AND SCOPE**Purpose:**

The purpose of this evaluation report supplement is to indicate that Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim, recognized in ICC-ES master evaluation report ESR-2922, has also been evaluated for compliance with the codes noted below.

Applicable code editions:

- 2017 Florida Building Code—Building
- 2017 Florida Building Code—Residential

2.0 CONCLUSIONS

The Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim, described in Sections 2.0 through 7.0 of the master evaluation report ESR-2922, complies with the *Florida Building Code—Building* and *Florida Building Code—Residential*, provided the design and installation are in accordance with the 2015 *International Building Code*® provisions noted in the master report.

Use of the Restoration Millwork® Exterior Trim and CertaTrim® Exterior Trim for compliance with the High-Velocity Hurricane Zone provisions of the *Florida Building Code—Building* and *Florida Building Code—Residential* has not been evaluated, and is outside the scope of this supplemental report.

For products falling under Florida Rule 9N-3, verification that the report holder's quality assurance program is audited by a quality assurance entity approved by the Florida Building Commission for the type of inspections being conducted is the responsibility of an approved validation entity (or the code official when the report holder does not possess an approval by the Commission).

This supplement expires concurrently with the evaluation report, reissued February 2020.